

## **PART VII**

### **ARTICLE 3 - Upgrade Requirement - Distance to Wetland**

No component of a subsurface sewage disposal system may be located within one hundred (100) feet of any wetland, inland and coastal area unless an approved enhanced nitrogen removal septic system with an approved form of disinfection has been approved by the Provincetown Board of Health. The Board of Health will review requests for a variance to this regulation on a case by case basis.